



**PETROTM OIL**

## Fuel Oil 180 CST

Property	Unit	Limit	Test Method
Ash	mass %	Max 0.1	ASTM D 482
Carbon Residue, Conradson	mass %	Max 12.0	ASTM D 189 or D 4530
Density at 15°C	kg/l	Max 0.98	ASTM D 1298 or D 4052
Flash Point, PMCC	°C	Min 66	ASTM D 93
Pour Point	°C	Max +24	ASTM D 97
Sediment	mass %	Max 0.15	ASTM D 473
Sulphur, Total	mass %	Max 2.0	ASTM D 1552 or D 2622 or D 4294
Viscosity at 50°C	cSt	Max 180	ASTM D 445
Water	vol%	Max 0.50	ASTM D 95